

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1213

Dated: 27/4/24

It is certified that an inspection team headed by Ankit Singh
(Name of Officers with designation) from P.H.E Officer PHED inspected the
NARAYANA E-TECHNO SCHOOL, Near Guna bypass A.B. Road, Shivupuri (M.P.) (Name & Address of
the school) on 27/4/24 (Date of inspection) and on the basis of Water Test Report (Attached) bearing
no. 1213 dated 26/4/24 Of (PHED Lab) certified that the **NARAYANA E-TECHNO SCHOOL**
(name of school) has safe drinking water facilities for the students and members of staff of the
institution. School is also maintaining the hygienic sanitation condition in the school building & the
campus as per norms prescribed by the Central/ State/U.T. Govt.

This certificate is valid till 27/4/26

मुख्य नगर पालिका अधिकारी
नगर पालिका परिषद शिवपुरी
Signature with Seal :
Name : Ankit Singh
Designation : P.H.E
Name & Address of the Office /Department : P.H.E

To

NARAYANA E-TECHNO SCHOOL
Near Guna bypass A.B. Road,
Shivupuri (M.P.)
(Name & Address of the Institution)

Note : The certificate is to be issued by authorized officer / PHED Lab / local bodies



Water Testing Laboratory 5 MGD
Nagar Nigam, Arera Hills, Bhopal

Test Report

Nature of sample :-Drinking Water		sampled by WT Lab 5 MGD NN		Unique Identification No.	
Sender's name and address TO,Narayana E-Techno School Guna By Pass Shivpuri M.P		Sender's letter no.		Sender's letter Date	
		WTL Ref. No		WTL receipt date	
		Date of analysis started		Date of analysis completed	
		Quantity Of sample		Ok	
		16.11.2023		17.11.2023	


Sample details

No.	Particulars of sample
1.	WATER SAMPLE
2	

RESULTS

No.	Characteristics/ Unit	test methods	BIS -10500:2012 Reaffirmed in Sep 2022		Results			
			Desirable Limit	Permissible Limit	1	2	3	4
1	2	3	4	5				
1	Colour in CU	IS 3025 Part 4: 2021	5	15	NIL			
2	Iron as Fe mg/l	APHA 23nd Edition,3500-fe B	1.0	1.0	NIL			
3	Nitrate as NO3 mg/l	APHA 23nd edition ,4500 NO3 -B	45	45	NIL			
4	pH pH Value at 25°C	IS 3025 Part 11: 1983	6.5 to 8.5	6.5 to 8.5	6.33			
5	Chloride as Cl mg/l	IS 3025 Part 32: 1988	250	1000	13.54			
6	Total Alkalinity as CaCO ₃ mg/l	IS 3025 Part 23: 1986	200	600	20			
7	Calcium as Ca ⁺⁺ mg/l	IS 3025 Part 40: 1991.	75	200	5.6			
8	Magnesium as Mg ⁺⁺ mg/l	APHA 23 rd edition, 3500 Mg-	30	100	3.84			
9	Turbidity in NTU	IS 3025 Part 10: 2023	1.0	5.0	0.2			
10	Total hardness as CaCO ₃ mg/l	IS 3025 PART 21: 2009	200	600	30			
11	Residual ChlorinePPM	-	0.2	1.0	-			
12	TDS By meter mg/l	IS 3025 Part 11: 1984	500	2000	36			
13	Manganese as Mg/l	Mn APHA 23nd edition 3500-mn-B	0.1	0.3	-			
14	Faecal coliform (TTC) pe 100 ml	APHA 23 rd edition, 9211 B	NIL for treated wter and water in distribution system		NIL			

- This report should not be produced partly or full without approval of signatory authority for legal purposes.
- It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but upto the limits indicated under the "permissible limit in the absence of alternate source" in column 4, above which the sources will have to be rejected.
- The results refer only to tested samples and parameters tested


 Quality Manager
CHENNAI
J M G.D. W.T. PLANT
Nagar Nigam, BHOPAL